

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 162

Date: 31/12/2024

It is certified that an inspection team headed by Arvind Kumar, J.E. (P.H.E.D) from P.H. Sub-Division, Araria West inspected that SCOTTISH PUBLIC SCHOOL, RAJOKHAR, ARARIA on Dated 05/09/2024 and found that the SCOTTISH PUBLIC SCHOOL, RAJOKHAR, ARARIA has Safe Drinking Water Facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above is valid for- One Year


 J.E. 31/12/2024
 P.H. Sub-Division,
 Araria West


 Signature With Seal :
 Name :- Amar Kumar
 Designation : - Assistant Engineer,
 P.H. Sub-Division, Araria West

(Name & Address of the Institution)


Principal
 Scottish Public School
 Rajokhar, Araria


FOR MANAGER
 SCOTTISH PUBLIC SCHOOL, ARARIA
 SMC

Letter No:-

130A-

Dated:-

7/9/2024

Government of Bihar

District Level Water Testing Laboratory Under, P.H.Div.Araria
Chemical and Bacteriological Report of Drinking Water Samples

District:- Araria

Water Sample are given by :- J.E(Araria)

Water Sample Received on Date:05-09-2024

Water Sample Received on Date:05-09-2024																
SL No	Location of Source	Test Result (in ppm)														
		NTU	Turbidity	P.H	Conductivity	Total Hardness	Total Alkalinity	Chloride	Iron	Calcium	Magnesium	Nitrate	T.D.S	As	F	Bacteria
1	2	3		4	5	6	7	8	9	10	11	12	13	14	15	16
1	Scottish Public School, Rajokhar(Araria)	1		7.2	161	94	46	22	0.34	22	7	BDL	105	-	-	-Ve
BIS 10500:2012 (second revision)	Desireable Limit	1		6.5-8.5	-	200	200	250	1	75	30	45	500	0.01	1	-Ve
	Permissible Limit in absence of alternate source	5		NR	-	600	600	1000	NR	200	100	NR	2000	NR	1.5	**

Note (i) BDL means below Detection Limit (ii) NR means Not Reportable

Note (i) BDL means below Detection Limit (ii) NR means no relaxation

Munira J Rubal

07/09/2024

Assistant Chemist
P.H.Div.Araria

Chemist

P.H.Div.Araria

07/09/2024
Assistant Chemist
P.H.Sub-Div.Araria

And Kaur

FOR MANAGER
SCOTTISH PUBLIC SCHOOL, ARARIA
SMC

Principal
Scottish Public School
Rajokhar, Araria